

MATERIAL REACTION TO FIRE CLASSIFICATION REPORT

prepared in compliance with amended 5 of the French Home Office Regulation
dated November 21st, 2002 (Official Gazette dated December 31, 2002)

Valid five years from issue date

REPORT N° 14-01840 L

MATERIAL presented by : ShowTex nv
Oude Gentweg 100
2070 Burcht
BELGIUM

TRADE NAME : MOLTON

BRIEF DESCRIPTION : 100% fireproofed cotton fabric
Nominal surface weight : 300 g/m²
Thickness : about 1.1 mm
Colours : various

TEST REPORT : N° 14-01840 dated September 17th, 2014

TESTS : Electrical burner test
Ageing in climatic room

CLASSIFICATION : **M 1**

CLASSIFICATION DURATION (appendix 22): Unlimited in indoor use
(material no washable and no dry cleaning)

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated June 3, 1994.


N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on September 17th, 2014

Director or empowered person

Bruno CHEVET

PO 



ACCREDITATION
N° 1-0101*
PORTÉE
COMMUNIQUÉE
SUR DEMANDE